


**Executive Order G-70-188**  
**Exhibit 2**  
**Figure 1B**

**Proper Installation of the A/L Adaptor**

**Correct Installation:** Note that the o-ring has isolated the shut-off port from the vapor holes



**Incorrect Installation:** Note that the o-ring includes the shut-off port with the vaporholes

